

EXHIBIT G



To:
Cc:
Bcc:
Subject: Fw: 2 more EIRs

From: webmaster@cpuc.ca.gov [<mailto:webmaster@cpuc.ca.gov>]
Sent: Friday, August 10, 2018 9:15 AM
To: usrb@cpuc.ca.gov
Cc: Cruz, Sheryll <SFQ2@pge.com>
Subject: Electric Safety Incident Reported- PG&E Incident No: 180810-8909

*******CAUTION: This email was sent from an EXTERNAL source. Think before clicking links or opening attachments.*******

The Following information regarding this incident has been reported:

Reporting Date: 8/10/2018 9:09:44 AM

Incident Date: 3/3/2018 @ 8:20 a.m.

Reported By: Sheryll Cruz, Sr Compliance Specialist

Utility Name: PG&E

Phone Number: (415)740-8929

Email Address: sfq2@pge.com

Incident Location: 6915 Tustin Road Salinas, Monterey

Reasons For Reporting:

- Fatalities? No (Utility: , Others:)
- Names of Fatalities:
- Injuries? (Utility: , Others:)
- Names of Injured:
- Damage? Yes (Utility: , Others:)
- Interruption? (Total Customers: 4, Total Hours: 2.5)
- Operator Judgement? No
- Media Coverage? No

Cause of Incident: Other (Other Cause: Blown/Failed Transformer)

Agencies on Scene:

Facilities Affected:

- Utilities Facilities: Prundale 1110
- Voltage (KV):
- Customer's Facilities:

DigIn Information:

- Excavator Name:
- Contact:
- Phone: () -

Incident Recovery:

- On Scene Date & Time: 3/3/2018 @ 8:20 a.m.
- Service Restored: 3/3/2018@ 10:50 a.m.

Summary: CPUC Reportable: Property Damage: On March 3, 2018, at approximately 8:17 AM, there was an outage affecting 4 customers on PG&E's Prundale 1110 circuit due to a blown/failed transformer at 6915 Tustin Rd, Salinas. On August 10, 2018, PG&E received a property damage claim from a customer alleging \$107,500 of damage to residence due to the incident. This information is preliminary.